

REMOTE FDC BOLLARD PROTECTION




REMOTE FIRE DEPARTMENT CONNECTION NOTES:

1. Clear space of 3 ft. shall be maintain around the fire hydrant. Building elements, signs, trees, bushes, shrubberies, or other landscaping shall not be located within the 3 ft. clear space or in front of the Remote FDC and bollards.
2. FDC shall be between 36 in. and 48 in. above grade.
3. Bollards shall be constructed as follows:
 - 3.1. Spaced 3 ft. from the face of the Remote FDC.
 - 3.2. Set not less than 3 ft. deep in a concrete footing of not less than 15 in. diameter.
 - 3.3. Top of the post shall not be less than 3 ft. above grade.
 - 3.4. Spaced not more than 4 ft. between posts.
 - 3.5. Constructed of steel not less than 4 in. diameter and concrete filled.
 - 3.6. Shall be painted traffic red and be reflective.


SIGNAGE NOTES:

1. Sign shall be directly located adjacent to the FDC.
2. Shall be mounted on a sign post that extends a minimum 6 ft. above grade.
3. Numerical building number shall be noted on the sign.
4. Sign shall be a minimum 8-in. X 12-in, sign that reads "DO NOT BLOCK BY ORDER OF FIRE MARSHAL".
5. Constructed of a minimum 0.080 aluminum sheet with 0.75 in. radius corners.
6. Font shall be ARIAL capitalized, 4 in. lettering and 1 in. width.
7. Sign face shall be traffic red. Lettering shall be white.
8. Sign shall be reflective.
9. Reference FDC Sign Package for specific requirements.

ELEVATION VIEW



PLAN VIEW



	FSCM NO	DWG NO	REV
		REMOTE FDC BOLLARD DETAIL	1
ISSUED	1 : 1	SHEET	1 OF 1